

 EZY CHEK SYSTEMS LEAK DETECTOR TEST AN ENVIRONMENTAL COMPLIANCE COMPANY 316 W. Indiana Ave. Chesterton, IN 46304 REVISION 8/21/2019				DATE AND TIME		3/13/2023		
				WEATHER		35 Snowy		
				COLLECT/INVOICE		Collected		
				CLIENT EMAIL		-		
				Testing Company Information				
Test Location Information				Certifications		Name		Midwest Tank Testing
PC # and WO #				Estabrooks: 82-1906		Address		316 W. Indiana Ave.
Name and FID #		Citgo - FID 16409		ICC: 10221928		City/State/Zip		Chesterton, IN 46304
Address		509 US Hwy 20		Indiana: UC 110386		Phone		800-975-1436
City/State/Zip		Michigan City, IN 46360		CP/STI: 16655		Technician Information		
Contact				UC111023		Name		Chris Zell
Phone						Email		support@midwesttanktesting.com
TYPE OF LEAK DETECTOR - (LD) or (ELD)								
PUMP #	PRODUCT			MODEL			SERIAL # (If Legible)	
1	Premium			TOKHEIM/FX1V			N/A	
2	Regular N.			TOKHEIM/Red Jacket			N/A	
3	Regular S.			Siphon			N/A	
4	Diesel			FX1DV			N/A	
5								
6								
7								
8								
LEAK DETECTOR TEST								
PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Results	
1	Premium	27	24	2160	189ml	2	Pass	
2	Regular				189ml		Fail	
3					189ml			
4					189ml			
5					189ml			
6					189ml			
7					189ml			
8					189 ml			
COMMENTS/RECOMMENDATIONS: DSL was down and they were doing some work to the STP. Reg went into high pressure immediately. DSL was down when testing. They were repairing the STP.								



AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W. Indiana Ave.
Chesterton, IN 46304

EZY CHEK SYSTEMS

PRODUCT LINE TEST

DATE AND TIME

3/13/2023

Test Location Information

PC # and WO #	
Name and FID #	Citgo - FID 9872
Address	509 US Hwy 20
City/State/Zip	Michigan City, IN 46360
Contact	
Phone	

Testing Company Information

Name	Midwest Tank Testing
Address	316 W. Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Chris Zell
Email	support@midwesttanktesting.com
Applied Pressure	1-1/2 Times Working Pressure, Min 50 PSI

PRODUCT LINE TEST - DATA (LT)

#1	Product Type:		Premium			
TIME	DATA	-/+	GPL	RES	GPH	
2:40	90	0	0.0037	0.0000	0.0000	
2:55	90	0	0.0037	0.0000	0.0000	
3:10	90	0	0.0037	0.0000	0.0000	
3:25	90	0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:			Pass			

#2	Product Type:		Regular			
TIME	DATA	-/+	GPL	RES	GPH	
2:40	0	0	0.0037	0.0000	0.0000	
2:55	0	0	0.0037	0.0000	0.0000	
3:10	0	0	0.0037	0.0000	0.0000	
3:25	0	0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:			Fail			

#3	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:						

#4	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:						

#5	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:						

#6	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:						

COMMENTS/RECOMMENDATIONS: I could not get the shut off valve on reg to work. I used the bullet and shear valves under disp to isolate the tank from the lines and I emptied 3 cylinders into the line and I could not get a canister to hold for more than 20 sec.



INDIANA HOMELAND SECURITY



Underground Storage Tank

CHRIS ZELL
316 W INDIANA AVE
CHESTERTON, INDIANA

STATE/PERMIT #

UC111987

ISSUE

12/29/2022

EFFECTIVE

12/30/2022

EXPIRATION

12/29/2024

DISCIPLINES

☒ Installation or Retrofitting

☐ Decommissioning Closure

☐ Cathodic Protection

☐ Decommissioning Removal

☐ Testing

The attached testing was completed at this site by an IDHS certified technician.

Technician's Signature: _____

Chris Zell



316 W. Indiana Ave.

Chesterton, IN 46304

(800) 975-1436

Serving the Midwest Since 1990