

 Midwest Tank Testing AN ENVIRONMENTAL COMPLIANCE COMPANY 316 W Indiana Ave. Chesterton, IN 46304		EZY CHEK SYSTEMS MECHANICAL LEAK DETECTOR TEST		DATE AND TIME 9-6-24 7:20-10:50 AM				
				WEATHER 63 SUNNY				
				COLLECT/INVOICE COLLECTED				
				CLIENT EMAIL -				
		Testing Company Information						
Test Location Information			Certifications		Name Midwest Tank Testing			
PC # and WO #			Estabrooks: 02-6669		Address 316 W Indiana Ave.			
Name and FID #		CITGO #16409	Veeder Root: B46257		City/State/Zip Chesterton, IN 46304			
Address		509 US HWY 20	Indiana: UC201511138C & UC111867		Phone 800-975-1436			
City/State/Zip		MICHIGAN CITY, IN 46360	Kentucky: IR0009779		Technician Information			
Contact			Illinois: 002401		Name Ryan Hartman			
Phone		219-221-6482	Franklin Fuel Systems: 1037623709		Cert # 02-6669			
MECHANICAL LEAK DETECTOR								
PUMP #		PRODUCT		MODEL		SERIAL # (If Legible)		
1		PREMIUM		FX1V		N/A		
2		REGULAR NORTH		RED JACKET		N/A		
3		REGULAR SOUTH		SIPHON		N/A		
4		DIESEL		FX1DV		N/A		
5								
6								
7								
8								
LEAK DETECTOR TEST								
PUMP #		Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ml/min	Opening Time	Results
1		PREMIUM	25	15	680	189ml	9	Pass
2		REGULAR NORTH	32	31	240	189ml	3	Pass
3		DIESEL	40	38	60	189ml	2	Pass
4						189ml		
5						189ml		
6						189ml		
7						189ml		
8						189ml		
COMMENTS/RECOMMENDATIONS:								



AN ENVIRONMENTAL COMPLIANCE COMPANY
316 W Indiana Ave.
Chesterton, IN 46304

EZY CHEK SYSTEMS

PRODUCT LINE TEST

DATE AND TIME

9-6-24 7:20-10:50 AM

WEATHER

63 SUNNY

COLLECT/INVOICE

COLLECTED

CLIENT EMAIL

Testing Company Information

Name

Midwest Tank Testing

Address

316 W Indiana Ave.

City/State/Zip

Chesterton, IN 46304

Phone

800-975-1436

Technician Information

Name

Ryan Hartman

Cert #

02-6669

Applied Pressure

1-1/2 Times Working Pressure, Min 50 PSI

Test Location Information

PC # and WO #

Name and FID #

CITGO #16409

Address

509 US HWY 20

City/State/Zip

MICHIGAN CITY, IN 46360

Contact

Phone

219-221-6482

PRODUCT LINE TEST - DATA (LT)

#1		Product Type:		PREMIUM		
TIME	DATA	-/+	GPL	RES	GPH	
9:31	54	0	0.0037	0.0000	0.0000	
9:46	51	-3	0.0037	-0.0111	-0.0444	
10:01	48	-3	0.0037	-0.0111	-0.0444	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:		Ball Valve	FINAL RESULT:		PASS	

#2		Product Type:		REGULAR NORTH		
TIME	DATA	-/+	GPL	RES	GPH	
9:31	36	0	0.0037	0.0000	0.0000	
9:46	34	-2	0.0037	-0.0074	-0.0296	
10:01	32	-2	0.0037	-0.0074	-0.0296	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:		Ball Valve	FINAL RESULT:		PASS	

#3		Product Type:		DIESEL		
TIME	DATA	-/+	GPL	RES	GPH	
8:22	90	0	0.0037	0.0000	0.0000	
8:37	90	0	0.0037	0.0000	0.0000	
8:52	90	0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:		ISO PLUG	FINAL RESULT:		PASS	

#4		Product Type:				
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:			FINAL RESULT:			

#5		Product Type:				
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:			FINAL RESULT:			

#6		Product Type:				
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:			FINAL RESULT:			

COMMENTS/RECOMMENDATIONS:

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

Underground Storage Tank




RYAN HARTMAN
316 W INDIANA AVENUE
CHESTERTON, IN 46304

STATE/PERMIT#
UC111867

ISSUED
4/16/2024

EFFECTIVE
4/16/2024



☒ Installation or Retrofitting
Expiration Date: 12/10/2024

☐ Decommissioning
Expiration Date:

☒ Cathodic Protection
Expiration Date: 3/1/2026

☒ Tank Tightness Testing
Expiration Date: 3/30/2026

The attached testing was completed at this site by an IDHS certified technician.

Technician's Signature: _____

Ryan Hartman



316 W. Indiana Ave.
Chesterton, IN 46304
(800) 975-1436
Serving the Midwest Since 1990