

AUTOMATIC TANK GAUGE
(ATG) FUNCTIONALITY
DATA SHEET

DATE AND TIME	9-6-24 7:20-10:50 AM
WEATHER	63 SUNNY
COLLECT/INVOICE	COLLECTED
CLIENT E-MAIL	

Testing Company Information

Test Location Infor	mation	Certifications	Name	Midwest Tank Testing	
PC # and WO #		Estabrooks: 02-6669	Address	316 W Indiana Ave.	
Name and FID #	CITGO #16409	Veeder Root: B46257	City/State/Zip	Chesterton, IN 46304	
Address	509 US HWY 20	Indiana: UC201511138C & UC111867	Phone 800-975-1436		
City/State/Zip	MICHIGAN CITY, IN 46360	Kentucky: IR0009779	Technician Information		
Contact		Illinois: 002401	Name	Ryan Hartman	
Phone	219-221-6482	Franklin Fuel Systems: 1037623709	Cert #	02-6669	

AUTOMATIC TANK GAUGE (ATG) FUNCTIONALITY TEST

This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

ATG Brand & Model	VR TLS 350					
Tank #	1	2	3	4		
Product Stored	PREMIUM	REGULAR NORTH	REGULAR SOUTH	DIESEL		
Tank Volume (gallons)	10152	10152	10152	10152		
Tank Diameter (inches)	96	96	96	96		
1. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced? (Yes/No)	Yes	Yes	Yes	Yes		
2. Float moves freely on the stem without binding? (Yes/No)	Yes	Yes	Yes	Yes		
3. Fuel float level agrees with the value programmed into the console? (Yes/No)	Yes	Yes	Yes	Yes		
4. Water float level agrees with the value programmed into the console? (Yes/No)	Yes	Yes	Yes	Yes		
5. Inch level from bottom of stem when 90% alarm is triggered.	81	81	81	81		
6. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge? (Yes/No)	Yes	Yes	Yes	Yes		
7. Inch level from the bottom when the water float first triggers an alarm.	2.5	2.5	2.5	2.5		
B. Inch level at which the water float alarm activates corresponds with value programmed in the gauge? (Yes/No)	Yes	Yes	Yes	Yes		
lf any answers in Lines 1,2,3 or 4 are "No,'	the system	has failed t	he test.			
Test Results (Pass/Fail)	Pass	Pass	Pass	Pass		

Comments:

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT



Underground Storage Tank





RYAN HARTMAN 316 W INDIANA AVENUE CHESTERTON, IN 46304

STATE/PERMIT#
UC111867

ISSUED 4/16/2024

4/16/2024

DISCIPLINES

Installation or Retrofitting Expiration Date: 12/10/2024

Cathodic Protection Expiration Date: 3/1/2026 Decommissioning Expiration Date:

Tank Tightness Testing Expiration Date: 3/30/2026

The attached testing was completed at this site by an IDHS certified technician.

Technician's Signature:

Ryan Hartman



316 W. Indiana Ave. Chesterton, IN 46304 (800) 975-1436

Serving the Midwest Since 1990

