

CITGO
502 HWY 20
M CITY IN 46360

FEB 5. 2024 2:04 PM

CSLD TEST RESULTS

FEB 5. 2024 2:04 PM

T 2:RNL NORTH
PROBE SERIAL NUM 754662

0.2 GAL/HR TEST
PER: FEB 5. 2024 PASS

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

0.2 GAL/HR TEST
PER: FEB 5. 2024 PASS

T 4:DIESEL
PROBE SERIAL NUM 616062

0.2 GAL/HR TEST
PER: FEB 5. 2024 PASS

***** END *****

CITGO
502 HWY 20
M CITY IN 46360

FEB 5. 2024 2:04 PM

LEAK TEST REPORT

T 2:RNL NORTH
PROBE SERIAL NUM 754662

NO TEST DATA AVAILABLE

***** END *****

CITGO
502 HWY 20
M CITY IN 46360

FEB 5. 2024 2:04 PM

LEAK TEST REPORT

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

NO TEST DATA AVAILABLE

***** END *****

CITGO
502 HWY 20
M CITY IN 46360

FEB 5. 2024 2:04 PM

LEAK TEST REPORT

T 4:DIESEL
PROBE SERIAL NUM 616062

NO TEST DATA AVAILABLE

***** END *****