

CITGO
502 HWY 20
M CITY IN 46360

JUL 13, 2024 2:52 PM

CSLD TEST RESULTS

JUL 13, 2024 2:52 PM

T 1:PREMIUM
PROBE SERIAL NUM 640325

0.2 GAL/HR TEST
PER: JUL 13, 2024 PASS

T 2:RNL NORTH
PROBE SERIAL NUM 754662

0.2 GAL/HR TEST
PER: JUL 13, 2024 PASS

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

0.2 GAL/HR TEST
PER: JUL 13, 2024 FAIL

T 4:DIESEL
PROBE SERIAL NUM 616062

0.2 GAL/HR TEST
PER: JUL 13, 2024 PASS

* * * * * END * * * * *

CITGO
502 HWY 20
M CITY IN 46360

JUL 13, 2024 2:52 PM

LEAK TEST REPORT

T 1:PREMIUM
PROBE SERIAL NUM 640325

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CITGO
502 HWY 20
M CITY IN 46360

JUL 13, 2024 2:52 PM

LEAK TEST REPORT

T 2:RNL NORTH
PROBE SERIAL NUM 754662

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CITGO
502 HWY 20
M CITY IN 46360

JUL 13, 2024 2:52 PM

LEAK TEST REPORT

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CITGO
502 HWY 20
M CITY IN 46360

JUL 13, 2024 2:52 PM

LEAK TEST REPORT

T 4:DIESEL
PROBE SERIAL NUM 616062

NO TEST DATA AVAILABLE

* * * * * END * * * * *