

CITGO
502 HWY 20
M CITY IN 46360

MAR 7, 2025 6:05 PM

CSLD TEST RESULTS

- - - - -
MAR 7, 2025 6:05 PM

T 1:PREMIUM
PROBE SERIAL NUM 640325

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

T 2:RNL NORTH
PROBE SERIAL NUM 754662

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

T 4:DIESEL
PROBE SERIAL NUM 616062

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

* * * * * END * * * * *

LEAK TEST STATUS:
TEST NOT IN PROGRESS