

CITGO
502 HWY 20
M CITY IN 46360

JUL 5, 2025 4:25 PM

CSLD TEST RESULTS

JUL 5, 2025 4:25 PM

T 1:PREMIUM
PROBE SERIAL NUM 640325

0.2 GAL/HR TEST
PER: JUL 5, 2025 PASS

T 2:RNL NORTH
PROBE SERIAL NUM 754662

0.2 GAL/HR TEST
PER: JUL 5, 2025 PASS

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

0.2 GAL/HR TEST
PER: JUL 5, 2025 PASS

T 4:DIESEL
PROBE SERIAL NUM 616062

0.2 GAL/HR TEST
PER: JUL 5, 2025 PASS

***** END *****

CITGO
502 HWY 20
M CITY IN 46360

JUL 5, 2025 4:25 PM

LEAK TEST REPORT

T 1:PREMIUM
PROBE SERIAL NUM 640325

NO TEST DATA AVAILABLE

***** END *****

CITGO
502 HWY 20
M CITY IN 46360

JUL 5, 2025 4:25 PM

LEAK TEST REPORT

T 2:RNL NORTH
PROBE SERIAL NUM 754662

NO TEST DATA AVAILABLE

***** END *****

CITGO
502 HWY 20
M CITY IN 46360

JUL 5, 2025 4:25 PM

LEAK TEST REPORT

T 3:RNL SOUTH
PROBE SERIAL NUM 704164

NO TEST DATA AVAILABLE

***** END *****

CITGO
502 HWY 20
M CITY IN 46360

JUL 5, 2025 4:25 PM

LEAK TEST REPORT

T 4:DIESEL
PROBE SERIAL NUM 616062

NO TEST DATA AVAILABLE

***** END *****