

CITGO
502 HWY 20
M CITY IN 46360

SEP 8. 2025 2:23 PM

SYSTEM STATUS REPORT

ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1:PREMIUM

VOLUME = 1513 GALS
ULLAGE = 8183 GALS
90% ULLAGE= 7213 GALS
TC VOLUME = 1504 GALS
HEIGHT = 20.47 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 68.3 DEG F

T 2:RNL NORTH

VOLUME = 1844 GALS
ULLAGE = 7852 GALS
90% ULLAGE= 6882 GALS
TC VOLUME = 1831 GALS
HEIGHT = 23.53 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 69.2 DEG F

T 3:RNL SOUTH

VOLUME = 1936 GALS
ULLAGE = 7760 GALS
90% ULLAGE= 6790 GALS
TC VOLUME = 1925 GALS
HEIGHT = 24.36 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.5 DEG F

T 4:DIESEL

VOLUME = 1568 GALS
ULLAGE = 6447 GALS
90% ULLAGE= 5645 GALS
TC VOLUME = 1563 GALS
HEIGHT = 24.01 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.0 DEG F

* * * * * END * * * * *