

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL. BY B&B EQUIPMENT

11/08/2024 3:41 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
PROBE 4	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

07/04/2016	3:14 AM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

TANK 2

02/06/2023	6:59 AM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH

TANK 3

09/16/2024	3:19 AM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

08/26/2024	3:19 AM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

02/05/2024	3:39 AM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

12/18/2023	3:19 AM
LEAK TEST	0,20 GPH
SLOPE	-0,03 GPH

12/04/2023	3:19 AM
LEAK TEST	0,20 GPH
SLOPE	-0,02 GPH

11/13/2023	3:29 AM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH

10/02/2023	3:19 AM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH

TANK 4

10/28/2024	12:59 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

10/07/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

09/09/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

08/12/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

07/08/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

06/10/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

05/13/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

04/22/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

04/01/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

03/04/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

02/05/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

01/08/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

12/18/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

11/20/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

10/30/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

PASSED SCALD TESTS

TANK 1
09/14/2024 7:03 AM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

02/23/2024 1:42 AM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

07/12/2022 2:53 AM
LEAK TEST 0,20 GPH
SLOPE 0,07 GPH

TANK 2
03/17/2023 2:26 AM
LEAK TEST 0,20 GPH
SLOPE -0,07 GPH

TANK 3
11/08/2024 1:25 PM
LEAK TEST 0,20 GPH
SLOPE -0,02 GPH

10/15/2024 8:43 PM
LEAK TEST 0,20 GPH
SLOPE 0,08 GPH

09/15/2024 11:15 PM
LEAK TEST 0,20 GPH
SLOPE 0,04 GPH

08/16/2024 11:39 PM
LEAK TEST 0,20 GPH
SLOPE -0,07 GPH

07/17/2024 11:47 PM
LEAK TEST 0,20 GPH
SLOPE 0,10 GPH

06/17/2024 7:48 PM
LEAK TEST 0,20 GPH
SLOPE -0,09 GPH

05/18/2024 6:05 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

04/20/2024 9:03 PM
LEAK TEST 0,20 GPH
SLOPE -0,03 GPH

03/21/2024 10:38 PM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

02/20/2024 8:16 AM
LEAK TEST 0,20 GPH
SLOPE 0,07 GPH

01/21/2024 10:26 PM
LEAK TEST 0,20 GPH
SLOPE -0,09 GPH

12/22/2023 10:23 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

11/22/2023 3:58 AM
LEAK TEST 0,20 GPH
SLOPE -0,02 GPH

10/23/2023	2:43 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

TANK 4

11/05/2024	3:40 AM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

10/13/2024	2:41 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

09/13/2024	7:28 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

08/14/2024	10:43 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

07/15/2024	11:38 PM
LEAK TEST	0,20 GPH
SLOPE	-0,03 GPH

06/16/2024	8:47 PM
LEAK TEST	0,20 GPH
SLOPE	-0,03 GPH

05/29/2024	12:37 AM
LEAK TEST	0,20 GPH
SLOPE	-0,03 GPH

04/28/2024	5:24 PM
LEAK TEST	0,20 GPH
SLOPE	-0,05 GPH

04/02/2024	9:38 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

03/03/2024	9:27 AM
LEAK TEST	0,20 GPH
SLOPE	-0,02 GPH

02/05/2024	10:10 AM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

01/10/2024	1:50 PM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH

12/11/2023	9:59 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

11/11/2023	8:35 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

10/12/2023	2:25 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH