

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL. BY B&B EQUIPMENT

04/10/2024 5:39 PM

SCALD TEST REPORT

UNLEAD 11886.0 GAL
UNLEAD

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 11:19 PM
TEST STARTED 02/15/2024
STATUS 1000,02
TEST ENDED 1:42 AM
TEST ENDED 02/23/2024

SLOPE -0,006 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL. BY B&B EQUIPMENT

04/10/2024 5:40 PM

SCALD TEST REPORT

UNLEAD 9403.0 GAL
UNLEAD

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 5:21 PM
TEST STARTED 03/16/2023
STATUS 0,02
TEST ENDED 2:26 AM
TEST ENDED 03/17/2023

SLOPE -0,073 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE