

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL, BY B&B EQUIPMENT

08/05/2024 4:30 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
PROBE 4	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

07/04/2016	3:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

TANK 2

02/06/2023	6:59 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

TANK 3

02/05/2024	3:39 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

12/18/2023	3:19 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

12/04/2023	3:19 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

11/13/2023	3:29 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

10/02/2023	3:19 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

09/11/2023	3:09 AM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH

02/06/2023	3:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

TANK 4

07/08/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

06/10/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

05/13/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

04/22/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

04/01/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

03/04/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

02/05/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

01/08/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

12/18/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

11/20/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

10/30/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

10/02/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

09/11/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

08/14/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

07/17/2023	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

PASSED SCALD TESTS

TANK 1

02/23/2024	1:42 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

07/12/2022	2:53 AM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH

TANK 2

03/17/2023	2:26 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

TANK 3

08/05/2024	1:05 PM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH

07/17/2024	11:47 PM
LEAK TEST	0.20 GPH
SLOPE	0.10 GPH

06/17/2024	7:48 PM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

05/18/2024	6:05 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

04/20/2024	9:03 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

03/21/2024	10:38 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

02/20/2024	8:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH

01/21/2024	10:26 PM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

12/22/2023	10:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

11/22/2023	3:58 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

10/23/2023	2:43 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

09/24/2023	11:11 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

08/25/2023	11:06 PM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

07/26/2023	11:59 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

TANK 4

08/05/2024	3:42 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

07/15/2024	11:38 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

06/16/2024	8:47 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

05/29/2024	12:37 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

04/28/2024	5:24 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH

04/02/2024	9:38 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

03/03/2024	9:27 AM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

02/05/2024	10:10 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

01/10/2024	1:50 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

12/11/2023	9:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

11/11/2023 8:35 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

10/12/2023 2:25 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

09/19/2023 12:58 AM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

08/21/2023 2:01 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

07/27/2023 10:13 AM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL, BY B&B EQUIPMENT

08/05/2024 4:31 PM

SCALD TEST REPORT

UNLEAD 11386,0 GAL
UNLEAD

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 11:19 PM
TEST STARTED 02/15/2024
STATUS 1000,02
TEST ENDED 1:42 AM
TEST ENDED 02/23/2024

SLOPE -0,006 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

UNLEAD 9403,0 GAL
UNLEAD

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 5:21 PM
TEST STARTED 03/16/2023
STATUS 0,02
TEST ENDED 2:26 AM
TEST ENDED 03/17/2023

SLOPE -0,073 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREM 9403,0 GAL
PREM

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 3:48 AM
TEST STARTED 08/05/2024
STATUS 0,02
TEST ENDED 1:05 PM
TEST ENDED 08/05/2024

SLOPE 0,069 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DIESEL 3018,0 GAL
DIESEL

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 11:25 AM
TEST STARTED 08/05/2024
STATUS 0,02
TEST ENDED 3:42 PM
TEST ENDED 08/05/2024

SLOPE 0,009 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE