

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	195	Contact Number	
Facility Name	BP	Contact email	
Address	5307 W. Wabash Ave, South Bend, IN 46619	Date of Inspection	07/09/23
Operator on Duty Name		Name of the Person Conducting Inspection	AKSHIT SHARMA

Operator Training

Operator Training

Operator Notified

☐ Yes

☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified

☐ Yes

☐ No

Release Detection Method

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Release Detection

☒ DTG

☒ BIM

☐ BIR

☐ IC

☐ Other

Spill Buckets

☐ Yes

☐ No

Operator Notified

☒ Yes

☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☐ Yes

☐ No

Operator Notified

☒ Yes

☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☐ Yes

☐ No

Operator Notified

☒ Yes

☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Are Sumps Clean and free from water, debris, product etc?

☐ Yes

☐ No

Operator Notified

☒ Yes

☐ No

Are UDCs clean and free from water, debris, product etc?

☐ Yes

☐ No

Operator Notified

☒ Yes

☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

Signature

Date

www.tanksdata.com

20220516