

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 195		Contact Number
Facility Name BP		Contact email
Address 5301 Western Ave South Bend		Date of Inspection 08/05/24
Operator on Duty Name m 46619		Name of the Person Conducting Inspection AKS/H/T
Operator Training		
Operator Training current	☐ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	Registration/Notification Form ☐ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Release Detection		
Release Detection Method	☒ ATG ☐ DTM	☐ BIR ☐ IC ☐ Other
Make and Model	FES TS 150	
Does it have paper?	☒ Yes ☐ No	Operator Notified ☒ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified ☒ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified ☒ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified ☒ Yes ☐ No
Spill Buckets		
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified ☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified ☒ Yes ☐ No
Fill Ports		
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Piping/STP Sumps		
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified ☒ Yes ☐ No
Under Dispenser Containments (UDC)		
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name
317-645-0215
tanksdata@gmail.com
Signature
Date
www.tanksdata.com