

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL, BY B&B EQUIPMENT

05/04/2024 12:52 PM

SCALD TEST REPORT

UNLEAD 11386,0 GAL
UNLEAD

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 11:19 PM
TEST STARTED 02/15/2024
STATUS 1000,02
TEST ENDED 1:42 AM
TEST ENDED 02/23/2024

SLOPE -0,006 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL, BY B&B EQUIPMENT

05/04/2024 12:53 PM

SCALD TEST REPORT

UNLEAD 9403,0 GAL
UNLEAD

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 5:21 PM
TEST STARTED 03/16/2023
STATUS 0,02
TEST ENDED 2:26 AM
TEST ENDED 03/17/2023

SLOPE -0,073 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL. BY B&B EQUIPMENT

05/04/2024 12:53 PM

SCALD TEST REPORT

PREM 9403.0 GAL
PREM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 5:17 AM
TEST STARTED 05/04/2024
STATUS 0.02
TEST ENDED 7:19 AM
TEST ENDED 05/04/2024

SLOPE -0.066 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110
INSTAL. BY B&B EQUIPMENT

05/04/2024 12:54 PM

SCALD TEST REPORT

DIESEL 3018.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 12:18 AM
TEST STARTED 04/26/2024
STATUS 0.02
TEST ENDED 5:24 PM
TEST ENDED 04/28/2024

SLOPE -0.047 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE