

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 195		Contact Number
Facility Name BP		Contact email
Address 5307 W Western Ave, South		Date of Inspection 09/02/24
Operator on Duty Name Bendin Y6619		Name of the Person Conducting Inspection AK SUIT

Operator Training current	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ ATG	☐ SIM	Operator Notified	☐ IC	☐ Other
Make and Model	TF-5 TS-5 D				
Does it have paper?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Under Dispenser Containments (UDC)	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com