

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	145	Contact Number	
Facility Name	BP	Contact email	
Address	5307 W. Western Ave	Date of Inspection	03/19/25
Operator on Duty Name	Scott Reed Ins-46619	Name of the Person Conducting Inspection	AKIT

Operator Training current

Operator Training
☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Release Detection Method

Release Detection
☒ ATG ☐ CIM

☐ SIR

☐ IC ☐ Other

Make and Model

FCS TRACON-TS 750

Does it have paper?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No

Operator Notified

☒ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified

☒ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified

☒ Yes ☐ No

Fill Ports

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Piping/STP Sumps

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified

☒ Yes ☐ No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com