



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

5/23/5

PRODUCT LINE TEST

Test Location Information

Name	FID 195
Address	5307 W Western Ave
City	South Bend, IN, 46619
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:25p	90	0	0.0037	0	0
12:40p	90	0	0.0037	0	0
12:55p	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:15pm	88	0	0.0037	0	0
1:30pm	87	-1	0.0037	.0037	.0148
1:45pm	87	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

PRODUCT LINE TEST

Test Location Information

Name	FID 195
Address	5307 W Western Ave
City	South Bend, IN, 46619
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Neither line has a ball valve. Used silver bullet plug to isolate.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 