

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 195
Address	5307 W Western Ave
City	South Bend, IN, 46619
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg 1	Fe Petro MLLD		
Prem	Red Jacket MLLD		
Reg 2	Siphon		
Diesel	European suction		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	29	12	180 ml	189ml	6 sec	Pass
2	Premium	25	20	100 ml	189ml	2 sec	Pass
3					189ml		.
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Technician Signature :

