

PRIMA LLOYD EXPRESS
5307 Western Ave
Savannah, GA 31406
578-288-9110
INSTALLED BY RRB EQUIPMENT
08/13/2025 6:27 PM
REGULATORY REPORT
HARDWARE STATUS

TS-CIR NOT INSTALLED
TS-ROH NOT INSTALLED
TS-SEN 1 NOT INSTALLED
TS-SEN 2 NOT INSTALLED
TS-CPH NOT INSTALLED
PRINTER OPERATIONAL
FAX/MOD OPERATIONAL

PROBES
PROBE 1 OPERATIONAL
PROBE 2 OPERATIONAL
PROBE 3 OPERATIONAL
PROBE 4 OPERATIONAL

AUXILIARY INPUTS
AUX IN 1 OPERATIONAL
AUX IN 2 OPERATIONAL

PASSED LEAK TESTS

TANK 1
07/04/2016 3:14 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
TANK 2
02/06/2023 6:59 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH
TANK 3
07/07/2025 3:24 AM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH
02/10/2025 2:39 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
12/16/2024 2:34 AM
LEAK TEST 0.20 GPH
SLOPE -0.00 GPH
11/25/2024 3:24 AM
LEAK TEST 0.20 GPH
SLOPE -0.06 GPH
11/11/2024 3:04 AM
LEAK TEST 0.20 GPH
SLOPE -0.09 GPH
09/16/2024 3:19 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
08/26/2024 3:19 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
02/05/2024 3:39 AM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH

TANK 4
08/04/2025 1:14 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH
07/21/2025 1:09 AM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH
06/23/2025 1:14 AM
LEAK TEST 0.20 GPH
SLOPE -0.02 GPH
05/26/2025 1:14 AM
LEAK TEST 0.20 GPH
SLOPE -0.04 GPH
05/05/2025 1:10 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH
04/07/2025 1:14 AM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH
03/10/2025 1:14 AM
LEAK TEST 0.20 GPH
SLOPE -0.03 GPH
02/10/2025 1:09 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH
01/20/2025 1:09 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH
12/23/2024 1:14 AM
LEAK TEST 0.20 GPH
SLOPE -0.00 GPH
11/25/2024 1:14 AM
LEAK TEST 0.20 GPH
SLOPE 0.01 GPH
10/28/2024 12:59 AM
LEAK TEST 0.20 GPH
SLOPE 0.00 GPH
10/07/2024 1:14 AM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH
09/09/2024 1:14 AM
LEAK TEST 0.20 GPH
SLOPE -0.00 GPH
08/12/2024 1:14 AM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH

PASSED SCALD TESTS

TANK 1
03/10/2025 1:08 AM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH
02/06/2025 1:35 AM
LEAK TEST 0.20 GPH
SLOPE 0.08 GPH
09/14/2024 7:03 AM
LEAK TEST 0.20 GPH
SLOPE 0.02 GPH
02/23/2024 1:42 AM
LEAK TEST 0.20 GPH
SLOPE -0.01 GPH

09/14/2024	LEAK TEST	7:03 AM
	SLOPE	0.20 GPH
		0.02 GPH
02/23/2024	LEAK TEST	1:42 AM
	SLOPE	0.20 GPH
		-0.01 GPH
TANK 2		
07/12/2025	LEAK TEST	5:20 AM
	SLOPE	0.20 GPH
		0.09 GPH
07/09/2025	LEAK TEST	8:51 AM
	SLOPE	0.20 GPH
		-0.07 GPH
03/15/2025	LEAK TEST	9:05 AM
	SLOPE	0.20 GPH
		-0.10 GPH
02/28/2025	LEAK TEST	1:55 AM
	SLOPE	0.20 GPH
		0.02 GPH
03/17/2023	LEAK TEST	2:26 AM
	SLOPE	0.20 GPH
		-0.07 GPH
TANK 3		
08/13/2025	LEAK TEST	12:37 PM
	SLOPE	0.20 GPH
		0.00 GPH
08/10/2025	LEAK TEST	10:58 PM
	SLOPE	0.20 GPH
		-0.04 GPH
07/11/2025	LEAK TEST	8:37 PM
	SLOPE	0.20 GPH
		-0.05 GPH
06/11/2025	LEAK TEST	11:54 PM
	SLOPE	0.20 GPH
		-0.03 GPH
05/12/2025	LEAK TEST	6:16 AM
	SLOPE	0.20 GPH
		-0.00 GPH
04/12/2025	LEAK TEST	9:47 PM
	SLOPE	0.20 GPH
		-0.04 GPH
03/13/2025	LEAK TEST	10:34 PM
	SLOPE	0.20 GPH
		0.01 GPH
02/11/2025	LEAK TEST	11:24 AM
	SLOPE	0.20 GPH
		-0.09 GPH
01/13/2025	LEAK TEST	5:11 AM
	SLOPE	0.20 GPH
		0.01 GPH
12/14/2024	LEAK TEST	11:17 PM
	SLOPE	0.20 GPH
		-0.01 GPH
11/14/2024	LEAK TEST	11:06 PM
	SLOPE	0.20 GPH
		0.04 GPH
10/15/2024	LEAK TEST	8:43 PM
	SLOPE	0.20 GPH
		0.08 GPH
09/15/2024	LEAK TEST	11:15 PM
	SLOPE	0.20 GPH
		0.04 GPH
08/16/2024	LEAK TEST	11:39 PM
	SLOPE	0.20 GPH
		-0.07 GPH
07/17/2024	LEAK TEST	11:47 PM
	SLOPE	0.20 GPH
		0.10 GPH
TANK 4		
08/13/2025	LEAK TEST	3:24 AM
	SLOPE	0.20 GPH
		0.02 GPH
07/16/2025	LEAK TEST	10:30 PM
	SLOPE	0.20 GPH
		0.01 GPH
06/16/2025	LEAK TEST	12:23 PM
	SLOPE	0.20 GPH
		-0.00 GPH
05/17/2025	LEAK TEST	4:26 AM
	SLOPE	0.20 GPH
		-0.01 GPH
04/17/2025	LEAK TEST	7:53 PM
	SLOPE	0.20 GPH
		0.00 GPH
03/23/2025	LEAK TEST	9:45 AM
	SLOPE	0.20 GPH
		-0.00 GPH
02/22/2025	LEAK TEST	10:42 AM
	SLOPE	0.20 GPH
		0.02 GPH
01/26/2025	LEAK TEST	6:00 AM
	SLOPE	0.20 GPH
		-0.03 GPH
12/31/2024	LEAK TEST	4:25 PM
	SLOPE	0.20 GPH
		0.09 GPH
12/03/2024	LEAK TEST	12:22 PM
	SLOPE	0.20 GPH
		-0.02 GPH
11/05/2024	LEAK TEST	3:40 AM
	SLOPE	0.20 GPH
		-0.00 GPH
10/13/2024	LEAK TEST	2:41 PM
	SLOPE	0.20 GPH
		-0.00 GPH
09/13/2024	LEAK TEST	7:28 PM
	SLOPE	0.20 GPH
		-0.01 GPH
08/14/2024	LEAK TEST	10:43 PM
	SLOPE	0.20 GPH
		-0.01 GPH
07/15/2024	LEAK TEST	11:38 PM
	SLOPE	0.20 GPH
		-0.03 GPH