

PRIYA LUCKY EXPRESS
5307 Western Ave
South Bend, In
574-288-9110

INSTAL. BY B&B EQUIPMENT

06/12/2025

6:42 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL
PROBE 4	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

07/04/2016	3:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

TANK 2

02/06/2023	6:59 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

TANK 3

02/10/2025	2:39 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

12/16/2024	2:34 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

11/25/2024	3:24 AM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH

11/11/2024	3:04 AM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

09/16/2024	3:19 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

08/26/2024	3:19 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

02/05/2024	3:39 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

TANK 4

05/26/2025	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

05/05/2025	1:10 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

04/07/2025	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

03/10/2025	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

02/10/2025	1:09 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

01/20/2025	1:09 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

12/23/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

11/25/2024	1:14 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

10/25/2024	12:59 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

1:14 AM

02/23/2024 LEAK TEST SLOPE	0.20 GPH 0.08 GPH 7:03 AM 0.20 GPH 0.02 GPH
03/15/2025 LEAK TEST SLOPE	1:42 AM 0.20 GPH -0.01 GPH
02/28/2025 LEAK TEST SLOPE	9:05 AM 0.20 GPH -0.10 GPH
03/17/2023 LEAK TEST SLOPE	1:55 AM 0.20 GPH 0.02 GPH
08/12/2025 LEAK TEST SLOPE	2:26 AM 0.20 GPH -0.07 GPH
06/11/2025 LEAK TEST SLOPE	1:54 PM 0.20 GPH -0.07 GPH
05/12/2025 LEAK TEST SLOPE	11:54 PM 0.20 GPH -0.03 GPH
04/12/2025 LEAK TEST SLOPE	8:16 AM 0.20 GPH -0.00 GPH
03/13/2025 LEAK TEST SLOPE	9:47 PM 0.20 GPH -0.04 GPH
02/11/2025 LEAK TEST SLOPE	10:34 PM 0.20 GPH 0.01 GPH
01/13/2025 LEAK TEST SLOPE	11:24 AM 0.20 GPH -0.09 GPH
12/14/2024 LEAK TEST SLOPE	5:11 AM 0.20 GPH 0.01 GPH
11/14/2024 LEAK TEST SLOPE	11:17 PM 0.20 GPH -0.01 GPH
10/15/2024 LEAK TEST SLOPE	11:06 PM 0.20 GPH 0.04 GPH
09/15/2024 LEAK TEST SLOPE	8:43 PM 0.20 GPH 0.08 GPH
08/16/2024 LEAK TEST SLOPE	11:15 PM 0.20 GPH 0.04 GPH
07/17/2024 LEAK TEST SLOPE	11:39 PM 0.20 GPH -0.07 GPH
06/17/2024 LEAK TEST SLOPE	11:47 PM 0.20 GPH 0.10 GPH
05/18/2024 LEAK TEST SLOPE	7:48 PM 0.20 GPH -0.09 GPH
	6:05 PM 0.20 GPH -0.01 GPH
TANK 4	
06/12/2025 LEAK TEST SLOPE	4:12 PM 0.20 GPH -0.01 GPH
05/17/2025 LEAK TEST SLOPE	4:26 AM 0.20 GPH -0.01 GPH
04/17/2025 LEAK TEST SLOPE	7:53 PM 0.20 GPH 0.00 GPH
03/23/2025 LEAK TEST SLOPE	9:45 AM 0.20 GPH -0.00 GPH
02/22/2025 LEAK TEST SLOPE	10:42 AM 0.20 GPH 0.02 GPH
01/26/2025 LEAK TEST SLOPE	6:00 AM 0.20 GPH -0.03 GPH
12/31/2024 LEAK TEST SLOPE	4:25 PM 0.20 GPH 0.09 GPH
12/03/2024 LEAK TEST SLOPE	12:22 PM 0.20 GPH -0.02 GPH
11/05/2024 LEAK TEST SLOPE	3:40 AM 0.20 GPH -0.00 GPH
10/13/2024 LEAK TEST SLOPE	2:41 PM 0.20 GPH -0.00 GPH
09/13/2024 LEAK TEST SLOPE	7:28 PM 0.20 GPH -0.01 GPH
08/14/2024 LEAK TEST SLOPE	10:43 PM 0.20 GPH -0.01 GPH
07/15/2024 LEAK TEST SLOPE	11:38 PM 0.20 GPH -0.03 GPH
06/16/2024 LEAK TEST SLOPE	8:47 PM 0.20 GPH -0.03 GPH
05/29/2024 LEAK TEST SLOPE	12:37 AM 0.20 GPH -0.03 GPH