

 Midwest Tank Testing AN ENVIRONMENTAL COMPLIANCE COMPANY 316 W Indiana Ave. Chesterton, IN 46304		EZY CHEK SYSTEMS MECHANICAL LEAK DETECTOR TEST		DATE AND TIME 5-10-23 7:55-10:25			
				WEATHER 50 SUNNY			
				COLLECT/INVOICE COLLECTED			
				CLIENT EMAIL -			
				Testing Company Information			
Test Location Information			Certifications	Name Midwest Tank Testing			
PC # and WO #		Estabrooks: 02-6669	Address 316 W Indiana Ave.				
Name and FID #	SUNOCO #16476	Veeder Root: B46257	City/State/Zip Chesterton, IN 46304				
Address	1911 US HWY 50	Indiana: UC201511138C & UC111867	Phone 800-975-1436				
City/State/Zip	BEDFORD, IN 47421	Kentucky: IR0009779	Technician Information				
Contact		Illinois: 002401	Name Ryan Hartman				
Phone	812-278-9155	Franklin Fuel Systems: 1037623709	Cert # 02-6669				
MECHANICAL LEAK DETECTOR							
PUMP #	PRODUCT	MODEL		SERIAL # (If Legible)			
1	REGULAR	FX1V		N/A			
2	PREMIUM	FX1V		N/A			
3	DIESEL	FX1V		N/A			
4							
5							
6							
7							
8							
LEAK DETECTOR TEST							
PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ml/min	Opening Time	Results
1	REGULAR	30	19	40	189ml	3	Pass
2	PREMIUM	31	20	50	189ml	4	Pass
3	DIESEL	34	26	290	189ml	6	Pass
4					189ml		
5					189ml		
6					189ml		
7					189ml		
8					189ml		
COMMENTS/RECOMMENDATIONS:							

Test Location Information

PC # and WO #	
Name and FID #	SUNOCO #16476
Address	1911 US HWY 50
City/State/Zip	BEDFORD, IN 47421
Contact	
Phone	812-278-9155

Testing Company Information

Name	Midwest Tank Testing
Address	316 W Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Ryan Hartman
Cert #	02-6669
Applied Pressure	1-1/2 Times Working Pressure, Min 50 PSI

PRODUCT LINE TEST - DATA (LT)

#1	Product Type:	REGULAR			
TIME	DATA	-/+	GPL	RES	GPH
9:05	58	0	0.0037	0.0000	0.0000
9:20	57	-1	0.0037	-0.0037	-0.0148
9:35	57	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
Isolation Method: Check Valve FINAL RESULT: PASS					

#2	Product Type:	PREMIUM			
TIME	DATA	-/+	GPL	RES	GPH
9:05	69	0	0.0037	0.0000	0.0000
9:20	67	-2	0.0037	-0.0074	-0.0296
9:35	66	-1	0.0037	-0.0037	-0.0148
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
Isolation Method: Check Valve FINAL RESULT: PASS					

#3	Product Type:	DIESEL			
TIME	DATA	-/+	GPL	RES	GPH
9:05	70	0	0.0037	0.0000	0.0000
9:20	69	-1	0.0037	-0.0037	-0.0148
9:35	68	-1	0.0037	-0.0037	-0.0148
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
Isolation Method: Check Valve FINAL RESULT: PASS					

#4	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
Isolation Method: FINAL RESULT:					

#5	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
Isolation Method: FINAL RESULT:					

#6	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
Isolation Method: FINAL RESULT:					

COMMENTS/RECOMMENDATIONS:



INDIANA HOMELAND SECURITY

Underground Storage Tank



RYAN HARTMAN
316 W INDIANA AVE
CHESTERTON, INDIANA

STATE/PERMIT #	ISSUE	EFFECTIVE	EXPIRATION
UC111867	12/12/2022	12/13/2022	12/10/2024

DISCIPLINES

- | | |
|--|--|
| ☒ Installation or Retrofitting | ☐ Decommissioning Closure |
| ☐ Cathodic Protection | ☐ Decommissioning Removal |
| ☐ Testing | |

The attached testing was completed at this site by an IDHS certified technician.

Technician's Signature: _____

Ryan Hartman



316 W. Indiana Ave
Chesterton, IN 46304
(800) 975-1436
Serving the Midwest Since 1990