

Oil
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility ID (FID) #	16476	Contact Number	
Facility Name	SUNOCO	Contact email	
Address	1911 US HWY 50E Bedford, IN 47421	Date of Inspection	05/03/24
Operator on Duty Name		Name of the Person Conducting Inspection	AKSHIT SAMPANAN

Operator Training current

Operator Training
☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Release Detection Method

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Release Detection
ATG

VR TL 5-350

SIR

IC

Other

☒ Yes ☐ No

☐ Yes ☒ No

Operator Notified

☐ Yes ☐ No

☐ Yes ☒ No

☐ Yes ☒ No

Operator Notified

☐ Yes ☐ No

☐ Yes ☒ No

☐ Yes ☒ No

Operator Notified

☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

Are the Spill Bucket in good condition and free of damage/cracks

Fill Ports
☐ Yes ☒ No

Operator Notified

☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☐ Yes ☒ No

Operator Notified

☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Piping/STP Sumps
☐ Yes ☒ No

Operator Notified

☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Containments (UDC)
☐ Yes ☒ No

Operator Notified

☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

Date

tanksdata@gmail.com

www.tanksdata.com