

CSLD TEST RESULTS
MAR 1, 2024 3:09 PM

STAR STOP
HWY 50
BEDFORD,IN

MAR 1, 2024 3:10 PM

CSLD TEST RESULTS
MAR 1, 2024 3:10 PM

T 1:UNLEADED
PROBE SERIAL NUM 183505
0.2 GAL/HR TEST
PER: MAR 1, 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 823606
0.2 GAL/HR TEST
PER: MAR 1, 2024 PASS

T 3:DIESEL
PROBE SERIAL NUM 213017
0.2 GAL/HR TEST
PER: MAR 1, 2024 PASS

***** END *****

STAR STOP
HWY 50
BEDFORD,IN

MAR 1, 2024 3:10 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 183505

NO TEST DATA AVAILABLE
***** END *****

STAR STOP
HWY 50
BEDFORD,IN

MAR 1, 2024 3:10 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 823606

NO TEST DATA AVAILABLE
***** END *****

STAR STOP
HWY 50
BEDFORD,IN

MAR 1, 2024 3:10 PM

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 213017

NO TEST DATA AVAILABLE
***** END *****

STAR STOP
HWY 50
BEDFORD,IN

MAR 1, 2024 3:10 PM

SYSTEM STATUS REPORT
- - - - -
ALL FUNCTIONS NORMAL
INVENTORY REPORT

T 1:UNLEADED
VOLUME = 8201 GALS
ULLAGE = 1799 GALS
90% ULLAGE= 799 GALS
TC VOLUME = 8261 GALS
HEIGHT = 62.65 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 49.4 DEG F

T 2:PREMIUM
VOLUME = 1417 GALS
ULLAGE = 3706 GALS
90% ULLAGE= 3193 GALS
TC VOLUME = 1419 GALS
HEIGHT = 30.00 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 57.3 DEG F

T 3:DIESEL
VOLUME = 1260 GALS