

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # <u>16476</u>		Contact Number
Facility Name <u>Shmoys</u>		Contact email
Address <u>1911 US Hwy 50E, Bedford</u>		Date of Inspection <u>04-20-25</u>
Operator on Duty Name <u>JW-47421</u>		Name of the Person Conducting Inspection <u>Mehon Singh</u>

Operator Training current	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	Registration/Notification Form		Operator Notified	☐ Yes	☐ No
Release Detection Method	Release Detection		Operator Notified	☐ Yes	☐ No
Make and Model	☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other		Operator Notified	☐ Yes	☐ No
Does it have paper?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

Signature

Date

www.tanksdata.com

Benjamin
no
empty