

GRAB N GO
1911 US-50
BEDFORD IN 47421

SEP 19, 2025 3:25 PM

CSLD TEST RESULTS

SEP 19, 2025 3:25 PM

T 1:UNLEADED
PROBE SERIAL NUM 183505

0.2 GAL/HR TEST
PER: SEP 19, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 450610

0.2 GAL/HR TEST
PER: SEP 19, 2025 PASS

T 3:DIESEL
PROBE SERIAL NUM 737166

0.2 GAL/HR TEST
PER: SEP 19, 2025 PASS

* * * * * END * * * * *

GRAB N GO
1911 US-50
BEDFORD IN 47421

SEP 19, 2025 3:25 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 183505

NO TEST DATA AVAILABLE

* * * * * END * * * * *

GRAB N GO
1911 US-50
BEDFORD IN 47421

SEP 19, 2025 3:25 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 450610

NO TEST DATA AVAILABLE

* * * * * END * * * * *

GRAB N GO
1911 US-50
BEDFORD IN 47421

SEP 19, 2025 3:25 PM

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 737166

NO TEST DATA AVAILABLE

* * * * * END * * * * *