



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date 8/11/25

PRODUCT LINE TEST

Test Location Information

Name	FID 16476
Address	1911 US 50
City	Bedford, IN, 47421
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:25p	90	0	0.0037	0	0
12:40p	90	0	0.0037	0	0
12:55p	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:15pm	90	0	0.0037	0	0
1:30pm	90	0	0.0037	0	0
1:45pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
2:05pm	88	0	0.0037	0	0
2:20pm	88	0	0.0037	0	0
2:35pm	88	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result :					



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 8/11/25

PRODUCT LINE TEST

Test Location Information

Name	FID 16476
Address	1911 US 50
City	Bedford, IN, 47421
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4		.
5		.
6		.

All three lines are in dirt STP' s with no visible ball valve; used silver bullet to isolate all three.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 