

IN-TANK SETUP

T 1: UNLEADED
PRODUCT CODE : 1
THERMAL COEFF : .000700
TANK DIAMETER : 96.00
TANK PROFILE : 4 PTS
FULL VOL : 9696
72.0 INCH VOL : 9438
48.0 INCH VOL : 5814
24.0 INCH VOL : 2190

FLOAT SIZE: 4.0 IN. 8496

WATER WARNING : 1.5
HIGH WATER LIMIT: 2.0

MAX OR LABEL VOL: 10005
OVERFILL LIMIT : 90%
: 9004
HIGH PRODUCT : 95%
: 9504
DELIVERY LIMIT : 10%
: 1000

LOW PRODUCT : 500
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00

MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 25%
: 2501

LEAK MIN ANNUAL : 25%
: 2501

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK: OFF

DELIVERY DELAY : 5 MIN

Oct 14, 2025 at
38.875345° N 86.4

GRAB N GO
1911 US-50
BEDFORD IN 47421

OCT 14, 2025 1:20 PM

SYSTEM STATUS REPORT

ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1: UNLEADED

VOLUME = 6942 GALS
ULLAGE = 2754 GALS
90% ULLAGE = 1784 GALS
TC VOLUME = 387 GALS
HEIGHT = 54.61 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 71.3 DEG F

Tank identified as FRP
programmed to 9,696
gallons

T 2: DIESEL
VOLUME = 1335 GALS
ULLAGE = 3275 GALS
TC VOLUME = 321 GALS
HEIGHT = 28.80 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 74.2 DEG F

T 3: DIESEL

VOLUME = 2000 GALS
ULLAGE = 3123 GALS
90% ULLAGE = 2610 GALS
TC VOLUME = 1990 GALS
HEIGHT = 38.06 INCHES
WATER VOL = 11 GALS
WATER = 1.35 INCHES
TEMP = 70.9 DEG F

***** END *****

Oct 14, 2025 at 1:
38.875345° N 86.43