



UST Tank Tightness Test

1. UST Facility Information

Agency Interest Number (AI)	26476		
UST Facility Name	Grab N Go		
UST Facility Physical Address	Street Address: 1911 US-50		
	City: Bedford	County: Lawrence	Zip Code: 47421

2. Test Information

Test Date	10/14/2025		
Next Test Date Due			
Reason for Test (mark only one)	☐ New Install (within 30 days from bringing into service) ☐ Repair (within 30 days) ☐ DEP Directed (specify): _____ ☐ Suspected Release – Incident #: _____ ☐ Other (specify): _____		
Test Type (mark all that apply)	Volumetric	Non-Volumetric	Other
	☐ Overfill ☐ Underfill	☒ Vacuum ☒ Ullage ☐ Tracer	☐ Interstitial ☐ Other (specify): _____
Leak Threshold	☒ 0.1 gph ☐ 0.05 gph ☐ 0.01 gph ☐ Other (specify): _____		
Test Method	Acoustic, Vacuum and Water Intrusion		
Test Duration and Delivery	Minimum Test Duration (min): 16min		Time Since Last Delivery (hr): >24hrs
Dispensing During Test	☐ Yes ☒ No		
Tanks Isolated During Test	☒ Yes ☐ No		
Groundwater Depth (ft)	67" BG		
Level Above Tank Bottom	☒ Yes ☐ No		

3. Tank Information (Attach additional pages as necessary)

Tank Number	1			
Substance Stored	Unleaded			
Capacity	9,696			
Diameter	96"			
Material	FRP			
Manufacturer				
Model				
Configuration	Round, Single Wall			
Number of Compartments	1			
Manifolded	No			
Leak Detection Method	CSLD			

4. Tank Tightness Test Data
(Columns are a continuation from Section 3)

Amount of Product in Tank (gal)	6,942			
Tank Percent Full (%)	72%			
Temperature of Product (°F)	71			
Amount of Water in Tank (inches)	0.0			
Pressure Measured at Tank Bottom (psi)	.5			
Test Duration (military)	11:51-12:07			
Calculated Lead Rate (gph)	0.0			

5. Test Results
(Columns are a continuation from Sections 3 and 4)

Double Wall Tank Secondary Containment	☐ Pass ☐ Fail ☒ N/A	☐ Pass ☐ Fail ☐ N/A	☐ Pass ☐ Fail ☐ N/A	☐ Pass ☐ Fail ☐ N/A
Ullage Portion of Tank	☒ Pass ☐ Fail ☐ N/A	☐ Pass ☐ Fail ☐ N/A	☐ Pass ☐ Fail ☐ N/A	☐ Pass ☐ Fail ☐ N/A
Results for Wet Portion of Tank	☒ Pass ☐ Fail ☐ N/A	☐ Pass ☐ Fail ☐ N/A	☐ Pass ☐ Fail ☐ N/A	☐ Pass ☐ Fail ☐ N/A
Repairs & Retest Required	☐ Yes ☒ No			
Release Reporting Required	☐ Yes ☒ No			
Comments	The testing was conducted using Estabrook EZY Locator Plus test equipment ND=Not Determined			

6. Certification

I certify that all the information provided on this document is true, accurate, and complete.

Tester Certification	Printed	Bryer LaMar		Date	10/14/2025
	Signature	<i>Bryer LaMar</i>			
License	Number: UC112187		Expiration Date: 3/31/26		
Certification Type (mark all that apply)	☐ Tank Manufacturer ☒ Test Equipment Manufacturer ☐ Other (specify):				
Contact Information	Phone: (812)425-4137		Email: compliance@hci4.com		
Company Name	Hinderliter Construction - 3601 N. St. Joseph Avenue Evansville, Indiana 47720				