

 Midwest Tank Testing AN ENVIRONMENTAL COMPLIANCE COMPANY 316 W Indiana Ave. Chesterton, IN 46304		EZY CHEK SYSTEMS		DATE AND TIME		10-12-22 8:15-14:00			
		MECHANICAL		WEATHER		60 CLOUDY			
		LEAK DETECTOR TEST		COLLECT/INVOICE					
				CLIENT EMAIL		-			
		Testing Company Information							
Test Location Information				Certifications		Name		Midwest Tank Testing	
PC # and WO #				Estabrooks: 02-6669		Address		316 W Indiana Ave.	
Name and FID #		PHILLIPS 66 #2830		Veeder Root: B46257		City/State/Zip		Chesterton, IN 46304	
Address		702 E LINCOLNWAY		Indiana: UC201511138		Phone		800-975-1436	
City/State/Zip		SOUTH BEND, IN 46601		Kentucky: IR0009779		Technician Information			
Contact				Illinois: 002401		Name		Ryan Hartman	
Phone				Franklin Fuel Systems: 1037623709		Cert #		02-6669	
MECHANICAL LEAK DETECTOR									
PUMP #	PRODUCT		MODEL		SERIAL # (If Legible)				
1	REGULAR		FE PETRO		N/A				
2	MID		FE PETRO		N/A				
3	PREMIUM		FE PETRO		N/A				
4	DIESEL		SUCTION		N/A				
5	KERO		SUCTION		N/A				
6									
7									
8									
LEAK DETECTOR TEST									
PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ml/min	Opening Time	Results		
1	REGULAR	28	12	150	189ml	3	Pass		
2	MID	NOT ENOUGH FUEL TO TEST					FAIL		
3	PREMIUM	29	22	450	189ml	3	Pass		
4					189ml				
5					189ml				
6					189ml				
7					189ml				
8					189ml				
THE MID GRADE TANK DOESN'T HAVE ENOUGH FUEL TO TEST THE LEAK DETECTOR.									