



AN ENVIRONMENTAL COMPLIANCE COMPANY
316 W Indiana Ave.
Chesterton, IN 46304

EZY CHEK SYSTEMS

PRODUCT LINE TEST

DATE AND TIME

10-12-22

8:15-14:00

WEATHER

60 CLOUDY

COLLECT/INVOICE

CLIENT EMAIL

Testing Company Information

Name

Midwest Tank Testing

Address

316 W Indiana Ave.

City/State/Zip

Chesterton, IN 46304

Phone

800-975-1436

Technician Information

Name

Ryan Hartman

Cert #

02-6669

Applied Pressure

1-1/2 Times Working Pressure, Min 50 PSI

Test Location Information

PC # and WO #

Name and FID #

PHILLIPS 66 #2830

Address

702 E LINCOLNWAY

City/State/Zip

SOUTH BEND, IN 46601

Contact

Phone

PRODUCT LINE TEST - DATA (LT)

#1	Product Type:		REGULAR			
TIME	DATA	-/+	GPL	RES	GPH	
10:30	61	0	0.0037	0.0000	0.0000	
10:45	58	-3	0.0037	-0.0111	-0.0444	
11:00	56	-2	0.0037	-0.0074	-0.0296	
11:15	54	-2	0.0037	-0.0074	-0.0296	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:			Ball Valve	FINAL RESULT:		PASS

#2	Product Type:		MID			
TIME	DATA	-/+	GPL	RES	GPH	
10:30	54	0	0.0037	0.0000	0.0000	
10:45	51	-3	0.0037	-0.0111	-0.0444	
11:00	49	-2	0.0037	-0.0074	-0.0296	
11:15	47	-2	0.0037	-0.0074	-0.0296	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:			Ball Valve	FINAL RESULT:		PASS

#3	Product Type:		PREMIUM			
TIME	DATA	-/+	GPL	RES	GPH	
10:30	37	0	0.0037	0.0000	0.0000	
10:45	34	-3	0.0037	-0.0111	-0.0444	
11:00	31	-3	0.0037	-0.0111	-0.0444	
11:15	28	-3	0.0037	-0.0111	-0.0444	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:			Ball Valve	FINAL RESULT:		PASS

#4	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:				FINAL RESULT:		

#5	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:				FINAL RESULT:		

#6	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
Isolation Method:				FINAL RESULT:		

COMMENTS/RECOMMENDATIONS: