

30 DAYS WALK THROUGH INSPECTION	
Tanks Data	
UST Facility I.D. (FID) #	2830
Facility Name	Phillips 66
Address	702 Lincolnway E S.B. 46601
Operator on Duty Name	Palwinder
Contact Number	
Contact email	
Date of Inspection	8/19/2022
Name of the Person Conducting Inspection	VIRENDER
Operator Training	
Operator Training current	☐ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Registration/Notification Form	
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No
Release Detection	
Release Detection Method	☒ ATG ☐ CIM ☐ SIR ☐ Other
Make and Model	VR TLS 450
Does it have paper?	☒ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Spill Buckets	
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No
Are the Spill Buckets in good condition and free of damage/cracks	☒ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Fill Ports	
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Piping/STP Sumps	
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No
Operator Notified	☐ Yes ☐ No
Under Dispenser Containments (UDC)	
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No
Operator Notified	☐ Yes ☐ No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.	
Operator on Duty Name	Signature
317-645-0215	Date
tanksdata@gmail.com	www.tanksdata.com
20220516	