

PL EXPD 66
762 LINCOLNWAY E
SOUTH BEND IN 46681
JN6288937483615

SENSOR STATUS REPORT - ALL SENSORS

NO DATA AVAILABLE

FEB 22, 2024 12:59 PM

PL EXPD 66
762 LINCOLNWAY E
SOUTH BEND IN 46681
JN6288937483615

TANK LEAK TEST HISTORY - PASSED TEST RESULTS

T 2: UNL

REPORT TYPE	DATE/TIME	METHOD	HOURS	AVERAGE	
				VOLUME	VOLUME
LAST PERIODIC	24/02/22 01:03	CSLD	31	2813	27.7
FULLEST PERIODIC	24/02/23 06:51	CSLD	28	3854	38.1
FULLEST PERIODIC	24/01/01 05:05	CSLD	29	3817	37.7
FULLEST PERIODIC	23/12/19 03:21	CSLD	23	4793	47.2
FULLEST PERIODIC	23/11/01 20:48	CSLD	34	3636	36.4
FULLEST PERIODIC	23/09/22 02:21	CSLD	34	4185	41.2
FULLEST PERIODIC	23/09/01 22:43	CSLD	26	2811	29.7
FULLEST PERIODIC	23/08/23 20:52	CSLD	26	3823	37.9
FULLEST PERIODIC	23/07/01 02:25	CSLD	26	3793	37.4
FULLEST PERIODIC	23/06/27 04:33	CSLD	23	3338	34.3
FULLEST PERIODIC	23/05/02 06:59	CSLD	26	3477	32.6
FULLEST PERIODIC	23/04/01 01:38	CSLD	25	3386	33.4
FULLEST PERIODIC	23/02/29 22:04	CSLD	23	3386	32.6
FULLEST PERIODIC	23/02/01 03:25	CSLD	27	2994	27.6
FULLEST PERIODIC	23/01/25 01:49	CSLD	37	5377	39.2
FULLEST PERIODIC	22/12/31 00:48	CSLD	23	3898	37.4
FULLEST PERIODIC	22/11/04 01:09	CSLD	27	3418	33.8
FULLEST PERIODIC	22/10/18 02:07	CSLD	23	2986	29.6
FULLEST PERIODIC	22/09/07 01:46	CSLD	20	3202	32.3
FULLEST PERIODIC	22/08/01 23:08	CSLD	22	3658	36.8
FULLEST PERIODIC	22/07/01 02:53	CSLD	28	3589	34.6
FULLEST PERIODIC	22/06/15 03:49	CSLD	21	4885	39.5
FULLEST PERIODIC	22/05/24 03:04	CSLD	22	3570	35.2
FULLEST PERIODIC	22/04/08 03:08	CSLD	21	3376	33.3
FULLEST PERIODIC	22/03/25 01:09	CSLD	22	3154	31.1
FULLEST PERIODIC	22/02/22 04:24	CSLD	22	2933	29.9
FULLEST PERIODIC	22/01/04 01:00	CSLD	19	4056	40.3
FULLEST PERIODIC	21/12/05 01:29	CSLD	21	4238	41.4
FULLEST PERIODIC	21/11/27 05:37	CSLD	21	4407	44.3
FULLEST PERIODIC	21/10/05 23:47	CSLD	19	5551	54.7
FULLEST PERIODIC	21/09/22 08:49	CSLD	26	5814	49.9
FULLEST PERIODIC	21/08/22 03:06	CSLD	22	3948	38.8
FULLEST PERIODIC	21/07/04 01:14	CSLD	25	4853	59.4
FULLEST PERIODIC	21/06/10 01:53	CSLD	24	5143	51.6
FULLEST PERIODIC	21/05/02 03:05	CSLD	27	5726	56.4
FULLEST PERIODIC	21/04/23 21:34	CSLD	25	4882	59.1
FULLEST PERIODIC	21/03/26 04:34	CSLD	29	3351	39.9

FEB 22, 2024 12:59 PM

PL EXPD 66
762 LINCOLNWAY E
SOUTH BEND IN 46681
JN6288937483615

TANK LEAK TEST HISTORY - PASSED TEST RESULTS

T 2: SPC

REPORT TYPE	DATE/TIME	METHOD	HOURS	AVERAGE	
				VOLUME	VOLUME
LAST PERIODIC	23/08/27 00:00	CSLD	16	687	7.3
FULLEST PERIODIC	23/08/12 00:00	CSLD	42	668	8.5
FULLEST PERIODIC	23/08/19 19:07	CSLD	35	695	8.7
FULLEST PERIODIC	23/08/14 09:31	CSLD	12	708	9.6
FULLEST PERIODIC	23/07/01 00:00	CSLD	43	640	8.1
FULLEST PERIODIC	23/06/07 16:22	CSLD	29	639	8.7
FULLEST PERIODIC	23/05/06 13:22	CSLD	28	681	8.6
FULLEST PERIODIC	23/02/05 00:00	CSLD	46	662	8.6
FULLEST PERIODIC	23/01/06 02:12	CSLD	15	794	10.1
FULLEST PERIODIC	22/10/10 00:00	CSLD	48	678	8.6
FULLEST PERIODIC	22/09/10 00:00	CSLD	48	678	8.6
FULLEST PERIODIC	22/08/04 18:10	CSLD	11	673	8.5
FULLEST PERIODIC	22/07/01 02:10	CSLD	19	635	8.8
FULLEST PERIODIC	22/06/29 19:30	CSLD	18	640	8.8
FULLEST PERIODIC	22/05/20 18:50	CSLD	11	639	8.1
FULLEST PERIODIC	22/04/12 00:00	CSLD	48	728	9.1
FULLEST PERIODIC	22/03/25 23:01	CSLD	41	724	9.2
FULLEST PERIODIC	22/02/12 04:58	CSLD	46	687	8.7
FULLEST PERIODIC	22/01/04 09:24	CSLD	64	632	10.5
FULLEST PERIODIC	22/12/31 21:31	CSLD	51	708	10.5
FULLEST PERIODIC	22/11/16 16:45	CSLD	32	708	10.5
FULLEST PERIODIC	22/10/01 01:08	CSLD	47	708	9.8
FULLEST PERIODIC	22/09/13 00:00	CSLD	38	708	9.8
FULLEST PERIODIC	22/08/14 19:16	CSLD	43	620	9.6
FULLEST PERIODIC	22/07/20 09:01	CSLD	51	638	11.7
FULLEST PERIODIC	22/06/29 19:02	CSLD	38	640	10.5