

0000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2830

Contact Number

Facility Name

Contact email

Address 700 Lincolnway E South Bend

Date of Inspection 05/09/24

Operator on Duty Name W, 46601

Name of the Person Conducting Inspection ALIYAT SHARAH

Operator Training current

Operator Training
☐ Yes ☒ No

Operator Notified ☐ Yes ☒ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☒ No

Operator Notified ☐ Yes ☒ No

Release Detection Method

Release Detection
☒ ATG ☐ TIM

Operator Notified ☐ Yes ☒ No

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Spill Buckets

☒ Yes ☐ No

Operator Notified ☐ Yes ☒ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☒ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified ☐ Yes ☒ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports
☒ Yes ☐ No

Operator Notified ☐ Yes ☒ No

Are Sumps Clean and free from water, debris, product etc?

Pipeline/STP Sumps
☒ Yes ☐ No

Operator Notified ☐ Yes ☒ No

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Containments (UDC)
☒ Yes ☐ No

Operator Notified ☐ Yes ☒ No

Operator on Duty Name

Signature

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

20220516