

AUG 13, 2025 1:08 PM

PL EXPO 66

702 LINCOLNWAY E

SOUTH BEND IN 46601

J06200937605015

TANK LEAK TEST HISTORY - PASSED TEST RESULTS

T 4: DSL

REPORT TYPE	DATE/TIME	METHOD	HOURS	AVERAGE VOLUME	% VOLUME
LAST PERIODIC	25/08/13 10:41	CSLD	101	519	17.3
FULLEST PERIODIC	25/08/12 16:40	CSLD	78	519	17.3
FULLEST PERIODIC	25/07/31 20:09	CSLD	83	519	17.3
FULLEST PERIODIC	25/06/01 03:42	CSLD	102	526	17.5
FULLEST PERIODIC	25/05/24 23:18	CSLD	12	534	17.8
FULLEST PERIODIC	25/04/01 01:07	CSLD	84	631	21.0
FULLEST PERIODIC	25/03/02 07:50	CSLD	14	784	26.1
FULLEST PERIODIC	25/01/13 08:00	CSLD	94	417	13.9
FULLEST PERIODIC	24/12/13 09:31	CSLD	59	477	15.9
FULLEST PERIODIC	24/11/10 03:22	CSLD	12	500	16.7
FULLEST PERIODIC	24/10/01 12:51	CSLD	74	464	15.5
FULLEST PERIODIC	24/09/01 02:22	CSLD	99	528	17.6
FULLEST PERIODIC	24/08/27 20:12	CSLD	57	534	17.8
FULLEST PERIODIC	24/07/11 16:57	CSLD	53	561	18.7
FULLEST PERIODIC	24/06/01 00:31	CSLD	95	513	17.1
FULLEST PERIODIC	24/05/18 03:16	CSLD	56	594	19.8
FULLEST PERIODIC	24/04/09 22:35	CSLD	70	507	16.9
FULLEST PERIODIC	24/03/08 01:23	CSLD	11	530	17.7
FULLEST PERIODIC	24/02/01 02:36	CSLD	59	434	14.5
FULLEST PERIODIC	24/01/18 10:58	CSLD	17	495	16.5
FULLEST PERIODIC	23/12/09 23:44	CSLD	57	491	16.4
FULLEST PERIODIC	23/11/01 18:59	CSLD	74	536	17.9
FULLEST PERIODIC	23/10/31 21:58	CSLD	74	536	17.9
FULLEST PERIODIC	23/09/22 23:49	CSLD	10	533	17.8
FULLEST PERIODIC	23/08/16 07:31	CSLD	76	546	18.2
FULLEST PERIODIC	23/07/28 18:16	CSLD	28	555	18.5
FULLEST PERIODIC	23/06/03 08:00	CSLD	54	583	19.4
FULLEST PERIODIC	23/05/13 02:31	CSLD	85	635	21.2
FULLEST PERIODIC	23/04/19 22:06	CSLD	63	598	19.9
FULLEST PERIODIC	23/03/29 06:13	CSLD	67	524	17.5
FULLEST PERIODIC	23/02/08 01:16	CSLD	13	532	17.7
FULLEST PERIODIC	23/01/01 00:12	CSLD	85	529	17.6
FULLEST PERIODIC	22/12/25 00:12	CSLD	69	594	19.8
FULLEST PERIODIC	22/11/26 15:12	CSLD	39	522	17.4
FULLEST PERIODIC	22/10/26 10:49	CSLD	63	496	16.5
FULLEST PERIODIC	22/09/24 06:49	CSLD	30	527	17.6

AUG 13, 2025 1:08 PM

PL EXPO 66

702 LINCOLNWAY E

SOUTH BEND IN 46601

J06200937605015

SENSOR STATUS REPORT - ALL SENSORS

NO DATA AVAILABLE