

TRIENNIAL INSPECTION

Facility Name: PHILLIPS 66 #2830 Test Date: 05/12/2025
 Facility Address: 702 Lincoln Way East South Bend IN. 46615
 Facility ID: 2830

SPILL CONTAINER INTEGRITY TESTING

Product	Mid							
Test Type	Initial							
Clean of liquid/debris	YES							
VISUAL INSPECTION	PASS							
Test Start Time	10:00							
Test End Time	11:00							
Starting Water Level (inches)	13							
Ending Water Level (inches)	13							
Water Level Change (inches)	0							
HYDROSTATIC TEST RESULT	PASS							
Double wall	NO							
Vacuum Test Length (minutes)								
Starting Inches of Water								
Ending Inches of Water								
VACUUM TEST RESULT								

Comments

Technician Name: Andrew Bakker

Dispatch # 7580

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19