



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date

4/14/25

PRODUCT LINE TEST

Test Location Information

Name	FID 2830
Address	702 Lincolnway E
City	South Bend, IN, 46601
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1	Product Type : Regular				
TIME	DATA	+/-	GPL	RES	GPH
12:50p	62	0	0.0037	0	0
1:05pm	59	-3	0.0037	.0111	.0444
1:20pm	57	-2	0.0037	.0074	.0296
1:35pm	55	-2	0.0037	.0074	.0296
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2	Product Type : Premium				
TIME	DATA	+/-	GPL	RES	GPH
1:55pm	58	0	0.0037	0	0
2:10pm	57	-1	0.0037	.0037	.0148
2:25pm	56	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3	Product Type : Mid-grade				
TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4	Product Type :				
TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date

4/14/25

PRODUCT LINE TEST

Test Location Information

Name	FID 2830
Address	702 Lincolnway E
City	South Bend, IN, 46601
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Mid-grade	.
4		.
5		.
6		.

Regular and premium ball valves do not isolate, used silver bullet for both.
The mid-grade currently is not hooked up to the UDC' s. Cannot test until reconnected.
Diesel line is European suction.

Comment :

Tester's Name : Josh Rider

Tester's Signature :