

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 2830
Address	702 Lincolnway E
City	South Bend, IN, 46601
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Mid	Fe Petro MLLD		
Prem	Fe Petro MLLD		
Dies	European suction		
Kero	European suction (not in use)		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	26	12	150 ml	189ml	3 sec	Pass
2	Mid-grade				189ml		.
3	Premium	28	20	380 ml	189ml	3 sec	Pass
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Mid-grade is currently not hooked up to the UDC' s. Cannot test until reconnected.

Technician Signature :

