

07/17/23 2:13 PM

14865 Lilly's 66 &
1992 ST RD 23
Ganger IN 46530
J16200937608002

Sensor Status Report -
All Sensors

NO DATA AVAILABLE

07/17/23 2:13 PM

14865 Lilly's 66 &
1992 ST RD 23
Ganger IN 46530
J16200937608002

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

07/17/23 2:14 PM

14865 Lilly's 66 &
1992 ST RD 23
Ganger IN 46530
J16200937608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: UNL

R: PORT TYPE = LAST PERIODIC
D: TE/ TIME = 07/17/23 5:18
M: THOD = CSLD Periodic Test
H: URS = 35
A: G. VOLUME = 6316
% VOLUME = 54.3

R: PORT TYPE = FULLEST PERIODIC
D: TE/ TIME = 07/17/23 5:18
M: THOD = CSLD Periodic Test
H: URS = 35
A: G. VOLUME = 6316
% VOLUME = 54.3

R: PORT TYPE = FULLEST PERIODIC
D: TE/ TIME = 06/11/23 4:51
M: THOD = CSLD Periodic Test
H: URS = 32
A: G. VOLUME = 6243
% VOLUME = 53.7

R: PORT TYPE = FULLEST PERIODIC
D: TE/ TIME = 05/07/23 2:57
M: THOD = CSLD Periodic Test
H: URS = 31
A: G. VOLUME = 6933
% VOLUME = 59.6

R: PORT TYPE = FULLEST PERIODIC
D: TE/ TIME = 04/22/23 3:38
M: THOD = CSLD Periodic Test
H: URS = 38
A: G. VOLUME = 6295
% VOLUME = 54.1

R: PORT TYPE = FULLEST PERIODIC
D: TE/ TIME = 03/03/23 5:27
M: THOD = CSLD Periodic Test
H: URS = 36
A: G. VOLUME = 6114