

08/07/24 3:17 PM

164865 Lilly's 66 &
14992 ST RD 23
Granger IN 46530
J06200937608002

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

08/07/24 3:17 PM

164865 Lilly's 66 &
14992 ST RD 23
Granger IN 46530
J06200937608002

Sensor Status Report -
All Sensors

NO DATA AVAILABLE

08/07/24 3:17 PM

164865 Lilly's 66 &
14992 ST RD 23
Granger IN 46530
J06200937608002

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: UNL

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/07/24 6:22
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 5754
% VOLUME = 49.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 1:22
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 7267
% VOLUME = 62.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/09/24 6:30
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 8930
% VOLUME = 77.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/19/24 6:16
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 8646
% VOLUME = 74.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/08/24 5:44
METHOD = CSLD Periodic Test