

12/20/24 5:24 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: RNL

REPORT TYPE = LAST PERIODIC
DATE/TIME = 12/20/24 5:26
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 3806
% VOLUME = 31.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/06/24 4:25
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 4889
% VOLUME = 40.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/28/24 5:27
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 5241
% VOLUME = 43.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/23/24 5:12
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 3691
% VOLUME = 30.7

12/20/24 5:24 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: PRM

REPORT TYPE = LAST PERIODIC
DATE/TIME = 12/20/24 11:18
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 1035
% VOLUME = 8.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 18:29
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 1063
% VOLUME = 8.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/26/24 8:00
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 1126
% VOLUME = 9.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/19/24 1:46
METHOD = CSLD Periodic Test
HOURS = 11
AVG. VOLUME = 1087
% VOLUME = 9.0

12/20/24 5:24 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 3: DSL East

REPORT TYPE = LAST GROSS
DATE/TIME = 12/20/24 16:22
METHOD = SLD Gross Test
AVG. VOLUME = 1328
% VOLUME = 11.0

REPORT TYPE = LAST PERIODIC
DATE/TIME = 12/20/24 14:32
METHOD = CSLD Periodic Test
HOURS = 39
AVG. VOLUME = 1366
% VOLUME = 11.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/01/24 2:46
METHOD = CSLD Periodic Test
HOURS = 71
AVG. VOLUME = 2445
% VOLUME = 20.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/27/24 12:58
METHOD = CSLD Periodic Test
HOURS = 67
AVG. VOLUME = 3071
% VOLUME = 25.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/31/24 4:24
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 2806
% VOLUME = 23.3

12/20/24 5:25 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 4: DSL West