

03/21/25 8:41 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

4: DSL West

03/21/25 8:40 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: RNL

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/21/25 6:28
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 6021
% VOLUME = 50.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/21/25 6:28
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 6021
% VOLUME = 50.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/20/25 1:21
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 6181
% VOLUME = 51.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/19/25 8:39
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 4771
% VOLUME = 39.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/06/24 4:25
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 4889
% VOLUME = 40.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/28/24 5:27
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 5241
% VOLUME = 43.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/23/24 5:12
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 3691
% VOLUME = 30.7

03/21/25 8:40 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: PRM

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/20/25 11:17
METHOD = CSLD Periodic Test
HOURS = 85
AVG. VOLUME = 1015
% VOLUME = 8.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/05/25 12:17
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 1083
% VOLUME = 9.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/28/25 12:36
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 1089
% VOLUME = 9.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/08/25 14:26
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 1243
% VOLUME = 10.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/24 20:33
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 1176
% VOLUME = 9.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/26/24 8:00
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 1126
% VOLUME = 9.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/19/24 1:46
METHOD = CSLD Periodic Test
HOURS = 11
AVG. VOLUME = 1087
% VOLUME = 9.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/19/24 1:46
METHOD = CSLD Periodic Test
HOURS = 11
AVG. VOLUME = 1087
% VOLUME = 9.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/19/24 1:46
METHOD = CSLD Periodic Test
HOURS = 11
AVG. VOLUME = 1087
% VOLUME = 9.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/19/24 1:46
METHOD = CSLD Periodic Test
HOURS = 11
AVG. VOLUME = 1087
% VOLUME = 9.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/19/24 1:46
METHOD = CSLD Periodic Test
HOURS = 11
AVG. VOLUME = 1087
% VOLUME = 9.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/19/24 1:46
METHOD = CSLD Periodic Test
HOURS = 11
AVG. VOLUME = 1087
% VOLUME = 9.0

03/21/25 8:41 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 3: DSL East

REPORT TYPE = LAST GROSS
DATE/TIME = 03/21/25 19:45
METHOD = SLD Gross Test
AVG. VOLUME = 1203
% VOLUME = 10.0

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/21/25 17:57
METHOD = CSLD Periodic Test
HOURS = 42
AVG. VOLUME = 1459
% VOLUME = 12.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/05/25 1:16
METHOD = CSLD Periodic Test
HOURS = 39
AVG. VOLUME = 2177
% VOLUME = 18.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/01/25 20:12
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 2225
% VOLUME = 18.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/30/25 19:50
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 2265
% VOLUME = 18.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/01/24 2:46
METHOD = CSLD Periodic Test
HOURS = 71
AVG. VOLUME = 2445
% VOLUME = 20.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/27/24 12:58
METHOD = CSLD Periodic Test
HOURS = 67
AVG. VOLUME = 3071
% VOLUME = 25.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/31/24 4:24
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 2806
% VOLUME = 23.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/31/24 4:24
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 2806
% VOLUME = 23.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/31/24 4:24
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 2806
% VOLUME = 23.3