



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

3/6/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 10566
Address	5316 W Western Ave
City	South Bend, IN, 46619
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket MLLD		
Prem	Red Jacket MLLD		
Dies 1	Red Jacket MLLD		
Dies 2	Red Jacket MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	27	22	270 ml	189ml	4 sec	Pass
2	Premium	24	14	200 ml	189ml	6 sec	Pass
3	Diesel 1	28	14	160 ml	189ml	4 sec	Pass
4	Diesel 2	-	-	-	189ml	-	.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Diesel 2 tank did not have enough gas to test. Pump won't run. Station currently not using Tank 4

Technician Signature :