

02/23/25 6:00 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: RNL

REPORT TYPE = LAST PERIODIC
DATE/TIME = 02/23/25 8:00
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 6039
% VOLUME = 50.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/20/25 1:21
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 6181
% VOLUME = 51.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/19/25 8:39
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 4771
% VOLUME = 39.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/06/24 4:25
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 4889
% VOLUME = 40.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/28/24 5:27
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 5241
% VOLUME = 43.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/23/24 5:12
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 3691
% VOLUME = 30.7

02/23/25 6:00 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: PRM

REPORT TYPE = LAST PERIODIC
DATE/TIME = 02/23/25 12:15
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 981
% VOLUME = 8.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/05/25 8:00
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 1048
% VOLUME = 8.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/08/25 14:26
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 1243
% VOLUME = 10.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/24 20:33
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 1176
% VOLUME = 9.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/26/24 8:00
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 1126
% VOLUME = 9.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/19/24 1:46
METHOD = CSLD Periodic Test
HOURS = 11
AVG. VOLUME = 1087
% VOLUME = 9.0

02/23/25 6:00 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 3: DSL East

REPORT TYPE = LAST GROSS
DATE/TIME = 02/23/25 16:44
METHOD = SLD Gross Test
AVG. VOLUME = 2488
% VOLUME = 20.7

REPORT TYPE = LAST PERIODIC
DATE/TIME = 02/23/25 14:26
METHOD = CSLD Periodic Test
HOURS = 54
AVG. VOLUME = 1703
% VOLUME = 14.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/01/25 20:12
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 2225
% VOLUME = 18.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/30/25 19:50
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 2265
% VOLUME = 18.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/01/24 2:46
METHOD = CSLD Periodic Test
HOURS = 71
AVG. VOLUME = 2445
% VOLUME = 20.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/27/24 12:58
METHOD = CSLD Periodic Test
HOURS = 67
AVG. VOLUME = 3071
% VOLUME = 25.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/31/24 4:24
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 2806
% VOLUME = 23.3

02/23/25 6:01 PM

Veldmans Marathon
5316 Western Ave
South Bend IN 46628
Z07296015405001

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 4: DSL West