

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	10566	Contact Number	
Facility Name	AMOCO	Contact email	
Address	5316 Western Ave	Date of Inspection	01127125
Operator on Duty Name	South Bend, IN 46619	Name of the Person Conducting Inspection	AK5H1T

Operator Training current	Operator Training	Registration/Notification Form	Release Detection
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Release Detection Method	☒ ATG ☐ DIM ☐ BIR		☐ IC ☐ Other
Make and Model	VR TIS 450P14		
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No

Spill Buckets	Spill Buckets	Spill Buckets	Spill Buckets
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No

Under Dispenser Containments (UDC)	Under Dispenser Containments (UDC)	Under Dispenser Containments (UDC)	Under Dispenser Containments (UDC)
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com