



AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W Indiana Ave
Chesterton, IN 46304

HYDROSTATIC SUMP
CONTAINMENT
(HSC/HDC) INTEGRITY TEST
DATA SHEET

Test Location Information

PC # and WO #	
Name and FID #	Marathon FID# 24742
Address	3204 Monroe St
City/State/Zip	LaPorte IN 46350
Contact	Lucky
Phone	219-369-6944

DATE AND TIME

9-27-21 8:15-12:15

WEATHER

85 Sunny

COLLECT/INVOICE

Collect

CLIENT E-MAIL

luckychotra95@gmail.com

Testing Company Information

Name	Midwest Tank Testing
Address	316 W Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Jason Muller
Cert #	68-4891

HYDROSTATIC STP SUMP CONTAINMENT (HSC) / HYDROSTATIC DISPENSER SUMP CONTAINMENT (HDC) INTEGRITY TEST

This procedure is to test the leak integrity of containment sumps. See PEI/RP1200 Section 6.5 for the test method.

Containment Sump ID	STP Sump	STP Sump						
Containment Sump Material	Regular	Premium						
Liquid and Debris Removed From Spill Bucket? (All liquids & debris must be disposed of properly) (Yes/No)	Yes	Yes						
Visual Inspection (No cracks, loose parts or separation of containment sump) If fail, omit hydrostatic test. (Pass/Fail)	Pass	Pass						
Containment Sump Depth (inches)	33	32						
Height From Bottom to Top of Highest Penetration (inches)	14	13						
Starting Water Level (inches)	18	17						
Test Start Time	10:35 AM	10:55 AM						
Ending Water Level (inches)	17	17						
Test End Time	11:35 AM	11:55 AM						
Test Period - Minimum 1 Hour (minutes)	60	60						
Water Level Change (inches)	1	0						

Pass/Fail Criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8"

Test Results (Pass/Fail)	Fail	Pass						
--------------------------	------	------	--	--	--	--	--	--

Comments: Only 1/4 inch was lost from the Regular sump containment in an hour. The containment looks to be in good shape; the problem is probably in one of the boots sealing the exit area of a pipe of conduit.