

 EZY CHEK SYSTEMS LEAK DETECTOR TEST AN ENVIRONMENTAL COMPLIANCE COMPANY 316 W. Indiana Ave. Chesterton, IN 46304 REVISION 8/21/2019				DATE AND TIME		9/20/22 - 12:15 PM		
				WEATHER		70 Sunny		
				COLLECT/INVOICE		Collected		
				CLIENT EMAIL		-		
				Testing Company Information				
Test Location Information				Certifications		Name		Midwest Tank Testing
PC # and WO #				Estabrooks: 82-1906		Address		316 W. Indiana Ave.
Name and FID #		Marathon - FID 24742		ICC: 10221928		City/State/Zip		Chesterton, IN 46304
Address		3204 Monroe St.		Indiana: UC 110386		Phone		800-975-1436
City/State/Zip		La Porte, IN 46350				Technician Information		
Contact						Name		Chris Zell
Phone						Email		support@midwesttanktesting.com
TYPE OF LEAK DETECTOR - (LD) or (ELD)								
PUMP #	PRODUCT		MODEL		SERIAL # (If Legible)			
1	Regular		FePetro/FX1V		N/A			
2	Premium		FePetro/FePetro		N/A			
3								
4								
5								
6								
7								
8								
LEAK DETECTOR TEST								
PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Results	
1	Regular	29	27	120	189ml	2	Pass	
2	Premium	27	25	210	189ml	3	Pass	
3					189ml			
4					189ml			
5					189ml			
6					189ml			
7					189ml			
8					189 ml			
COMMENTS/RECOMMENDATIONS:								



AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W. Indiana Ave.
Chesterton, IN 46304

EZY CHEK SYSTEMS

PRODUCT LINE TEST

DATE AND TIME

9/20/22 - 12:15 PM

Test Location Information

PC # and WO #	
Name and FID #	Marathon - FID 24742
Address	3204 Monroe St.
City/State/Zip	La Porte, IN 46350
Contact	
Phone	

Testing Company Information

Name	Midwest Tank Testing
Address	316 W. Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Chris Zell
Email	support@midwesttanktesting.com
Applied Pressure	1-1/2 Times Working Pressure, Min 50 PSI

PRODUCT LINE TEST - DATA (LT)

#1	Product Type:		Regular		
TIME	DATA	-/+	GPL	RES	GPH
12:30	77	0	0.0037	0.0000	0.0000
12:45	77	0	0.0037	0.0000	0.0000
13:00	77	0	0.0037	0.0000	0.0000
13:15	77	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#2	Product Type:		Premium		
TIME	DATA	-/+	GPL	RES	GPH
12:30	81	0	0.0037	0.0000	0.0000
12:45	81	0	0.0037	0.0000	0.0000
13:00	81	0	0.0037	0.0000	0.0000
13:15	81	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#3	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#4	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#5	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#6	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

COMMENTS/RECOMMENDATIONS: