

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # <u>24772</u>		Contact Number
Facility Name <u>MARATHON</u>		Contact email
Address <u>3204 MONROE ST, LA PORTE, IN 46350</u>		Date of Inspection <u>12/15/24</u>
Operator on Duty Name <u>AKSHAT</u>		Name of the Person Conducting Inspection <u>AKSHAT</u>

Operator Training current	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Registration/Notification Form	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ ATG	☐ TIM	Operator Notified	☐ Yes	☐ No
Make and Model	<u>VR T-LS 350</u>	☐ SIR	Operator Notified	☐ Yes	☐ No
Does it have paper?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Spill Buckets	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Fill Ports	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Pipeline/STP Sumps	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Under Dispenser Containments (UDC)	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____
 317-645-0215 tanksdata@gmail.com www.tanksdata.com