

MAES MART
LAPORTE IN 46360
LAPORTE IN 46350

JUN 8, 2024 3:20 PM

CSLD TEST RESULTS

JUN 8, 2024 3:20 PM

T 1:RNL
PROBE SERIAL NUM 496196

0.2 GAL/HR TEST
PER: JUN 8, 2024 PASS

T 3:PNL
PROBE SERIAL NUM 625407

0.2 GAL/HR TEST
PER: JUN 8, 2024 PASS

***** END *****

MAES MART
LAPORTE IN 46360
LAPORTE IN 46350

JUN 8, 2024 3:20 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 496196

NO TEST DATA AVAILABLE

***** END *****

MAES MART
LAPORTE IN 46360
LAPORTE IN 46350

JUN 8, 2024 3:20 PM

LEAK TEST REPORT

T 3:PNL
PROBE SERIAL NUM 625407

NO TEST DATA AVAILABLE

***** END *****