

MAES MART
3204 MONROE ST
LAPORTE IN 46350

OCT 10, 2025 5:16 PM

CSLD TEST RESULTS

OCT 10, 2025 5:16 PM

T 1:RNL

PROBE SERIAL NUM 496196

0.2 GAL/HR TEST

PER: OCT 10, 2025 PASS

T 3:PNL

PROBE SERIAL NUM 625407

0.2 GAL/HR TEST

PER: OCT 10, 2025 PASS

* * * * * END * * * * *

MAES MART
3204 MONROE ST
LAPORTE IN 46350

OCT 10, 2025 5:16 PM

LIQUID STATUS

OCT 10, 2025 5:16 PM

L 1:RUL STP
SENSOR NORMAL

L 2:PUL STP
SENSOR NORMAL

* * * * * END * * * * *