

MAES MART
LAPORTE IN 46360
LAPORTE IN 46350

MAR 7, 2025 3:41 PM

CSLD TEST RESULTS

MAR 7, 2025 3:41 PM

T 1:RNL
PROBE SERIAL NUM 496196

0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

T 3:PNL
PROBE SERIAL NUM 625407

0.2 GAL/HR TEST
PER: MAR 6, 2025 PASS

* * * * * END * * * * *

MAES MART
LAPORTE IN 46360
LAPORTE IN 46350

MAR 7, 2025 3:41 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 496196

NO TEST DATA AVAILABLE

* * * * * END * * * * *

MAES MART
LAPORTE IN 46360
LAPORTE IN 46350

MAR 7, 2025 3:41 PM

LEAK TEST REPORT

T 3:PNL
PROBE SERIAL NUM 625407

NO TEST DATA AVAILABLE

* * * * * END * * * * *

LEAK TEST STATUS:
TEST NOT IN PROGRESS